

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## Cape Canaveral Space Force Station (PWS ID# 3054140) Has Levels of Disinfection Byproducts (DBPs) Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for the presence of DBPs on a quarterly basis. The DBPs test results from our 2nd Quarter samples recorded an increase in total trihalomethanes (TTHM) exceeding the standards, or maximum contaminant level (MCL) during the reporting period ending on April 7, 2021. The MCL for TTHM is calculated based on locational running annual averages (LRAA) of samples collected from the last four quarters. Results from the 2nd Quarter increased our LRAA for TTHM to 0.081 mg/L at CX 11. This value exceeds the respective MCLs for TTHM of 0.080 mg/L.

### **What should I do?**

At this time, **no** alternative source of water is necessary. However, if you have any specific health concerns, consult your doctor.

### **What does this mean?**

This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing TTHM in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

### **What Happened? What is being done?**

Beginning March 8, 2021 and continuing through April 16, 2021, the City of Cocoa temporarily changed its water disinfection method for free-chlorine. During this period, Cape Canaveral Space Force Station experienced very high TTHM levels. Monthly screening sample results showed TTHM levels returned to normal levels by April 19, 2021. Cape Canaveral Space Force Station will continue to conduct quarterly compliance samples and monthly screening samples to monitor the system for any deviations.

Please direct any questions to the Bioenvironmental Engineering office at (321) 494-5435, or email [usaf.patrick.45sw-mdg.list.45omrs-bioenvironmental@mail.mil](mailto:usaf.patrick.45sw-mdg.list.45omrs-bioenvironmental@mail.mil).